

ALLNET ALL369x-D0-01 / Optical D-0 read head for ALL3691

>>> Go to the shop article





D0 sensor for ALL3691 for removing the D0 signal to modern electricity meters.

The D0 signal is usually every 2 seconds automatically sent from the electricity meter of the energy supplier in the infrared range.

Since each type of construction D0 electricity meter has a different shape, the ALLNET D0 sensor is individually attached to the meter (e.g. with tape).

Accessories

Part No.	Name
118725	ALLNET ALL3696 / Powermeter ALL3696 IP with 2x induction



ALLNET GmbH - Maistraße 2 - 82110 Germering - sales@allnet.de - 089 / 894 222 22 Errors and technical changes that serve the interests of progress or development of the product, are reserved.